

Township of Edwardsburgh Cardinal

Cardinal WTP UV Replacement

ADDENDUM NO. 4

ISSUED: April 3rd, 2025

This addendum is issued prior to receipt of tenders and shall amend and/or clarify the work from the following questions/items:

- Q1)** We make a request to please extend the bid to ascertain tariff ramifications by one week.
- A1)** H2Flow confirms that there are not tariffs on the UV system. The closing date shall remain 2:00 pm, April 8th, 2025.

- Q2)** Please allow electronic bid submissions.
- A2)** Electronic bid submissions will not be accepted.

- Q3)** Please also provide the list of those who attended the Mandatory Meeting.
- A3)** List of attendees at the mandatory site meeting is attached.

- Q4)** Could you confirm if the flange size of the existing equipment matches that of the new UV kit, if not more work will be required for installation. Could you please provide the specifications for the existing equipment and the dimensions of the new UV kit.
- A4)** The new UV system is a like for like replacement of the existing system. The new system shall have identical flange-to-flange length and flange diameter as the existing system.

Attachments:

1. Attendees at Mandatory Site Meeting

END OF ADDENDUM

Attendees at Mandatory Site Meeting:

- 1) Jeffrey Wallace Construction
- 2) Ladouceur Mechanical
- 3) IECBL
- 4) Black and McDonald
- 5) Eastern Welding
- 6) Filtrum