

Township of Edwardsburgh Cardinal

Public Works Department



Addendum 1 Tender for New and Replacement Asphalt Sidewalk RFQ No. EC-PW-25-13

Issued May 28, 2025

Purpose: The Township has prepared this addendum in response to inquiries related to the Tender for New and Replacement Asphalt Sidewalks issued on May 20, 2025.

Question 1: Will **geotextile fabric** be required beneath the granular base? If so, should we factor that into our price?

Answer 1: Geotextile fabric is not required beneath granular base

Question 2: Would it be acceptable for us to drive our machinery (20 ton dump truck) over the grass if we restore any disturbed areas to their original condition afterward?

Answer 2: We anticipate that in order to complete some of the work that equipment will need to go over the grass area. The grass area should be to the south of the sidewalk on County Rd 2.

Question 3: Do the two tie-ins per property (one near the house and one by the road) count as **one tie-in or two**?

Answer 3: North and South of the sidewalk count as one driveway tie-in. Anticipate about a one foot distance for tie-in.

Question 4: Do the 500 tonnes of Granular A listed in the tender apply exclusively to areas outside the new and replacement sidewalk scopes, or does this quantity include the material needed for the sidewalks and tie-ins?

Answer 4: The granular A estimated quantity should be sufficient material needed for both the sidewalks and tie-ins.

Question 5: Could you please confirm the expected project start date and the deadline for substantial completion?

Answer 5: Anticipate start date of project would anytime after June 24th and project completed by no later than August 27, 2025.

End of Addendum